

Manager: James Vandiver
Address: City Hall, 131 Cross Street
Meetings: 131 Cross Street

Contact: James Vandiver
Mortons Gap, KY 42440

Phone: 270-258-5362

Public Meetings 1st Monday of each month at 7:00 pm

We purchase our water from the South Hopkins Water District which is purchased from Dawson Springs Water System. Their source is Lake Beshears which is classified as surface water. Sources of impact include chemical storage facilities, landfills, underground storage tanks, auto repair shops, oil/gas wells highways, bridges, waste water treatment plants, golf courses, cemeteries, septic systems, and agricultural. An analysis of the overall susceptibility is generally moderate for Lake Beshears. This is a summary of an assessment. The Grape Vine area is served the City of Madisonville. Madisonville utilizes surface water from Lake PeeWee, Sources of impact include chemical storage facilities, underground storage tanks, highways, septic systems, and agricultural. An analysis of the overall susceptibility is generally moderate for Lake Pee Wee. The complete reports are available at the Pennyriple Area Development office in Hopkinsville, located at 300 Hammond Drive Hopkinsville, 42240. (270) 886-9484. They can also be obtained at Mortons Gap City Hall 102 South Main Street, Mortons Gap Kentucky 42440, (270) 258-5362.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/L). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth.

Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Copies of this report are available upon request by contacting our office during business hours. **A= Dawson Springs Water & Sewer (Purchased through South Hopkins Water District), B= Mortons Gap Water Department**

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

	Allowable Levels	Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% monthly samples	A=	0.09	99	No	Soil runoff

Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------	--------------	--------------------	----------------	-----------	--------------------------------

Inorganic Contaminants

Barium [1010] (ppm)	2	2	A=	0.024	0.024 to 0.024	Feb-18	No	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	B=	0.036 (90 th percentile)	0.0058 to 0.0435	Sept-16	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	A=	0.7	0.7 to 0.7	Feb-18	No	Water additive which promotes strong teeth

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	A=	1.56	1.27 to 2.08	2018	No	Naturally present in environment.
---	-----	-----	----	------	--------------	------	----	-----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	B=	1.17 (highest average)	1.02 to 1.28	2018	No	Water additive used to control microbes.
Chlorite (ppm)	1	0.8	A=	0.560 (average)	0.07 to 0.58	2018	No	Byproduct of drinking water disinfection.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	B=	48 (average)	27 to 54 (range of individual sites)	2018	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	B=	53 (average)	37 to 74 (range of individual sites)	2018	No	Byproduct of drinking water disinfection.

This report will not be sent to individual customers. It will be available at City Hall.

NOTICES OF VIOLATION / 2019 - 7209306 CHLORINE, 2019 - 7209305 MOR, 2018 - 7209304 MOR

NOTICE OF VIOLATION 2019 - 7209304 MOR, FAILURE TO SUBMIT Description of Non Compliance: 401 KAR 8:20 MONTHLY OPERATING REPORT The public water system failed to submit the Monthly Operational Report for the compliance period 04/01/2018 - 04/30/2018. **Comments:** MOR Late: The April 2018 MOR was mailed to the Division of Water on 05/15/18. MORs must be placed in the mail before the 10th to be received by Division of Water on time. **Remedial Measures:** Submit the MOR, if available to the Division of Water within 30 days of receipt of this Notice of Violation. Our system has submitted the April 2018 MOR to our primacy agency. Perform Public Notification and the required Certification. Detail this NOV in the 2018 CCR.

NOTICE OF VIOLATION 2019 - 7209305 MOR, FAILURE TO SUBMIT Description of Non Compliance: 401 KAR 8:20 MONTHLY OPERATING REPORT The public water system failed to submit the Monthly Operational Report for the compliance period 03/01/2019 - 03/31/2019. **Comments:** System failed to submit MOR for March 2019 monitoring period. MORs must be placed in the mail before the 10th to be received on time. **Remedial Measures:** Submit the MOR, if available to the Division of Water within 30 days of receipt of this Notice of Violation. Our system has submitted the March 2019 MOR to our primacy agency. Perform Public Notification and the required Certification. Detail this NOV in the 2018 CCR.

Notice of Violation / 2019 - 7209306 CHLORINE

Our water system violated one or more drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 03/01/2019 - 03/31/2019 we did not complete all monitoring or testing for 0999 CHLORINE and therefore cannot be sure of the quality of your drinking water during that time.

There is nothing you need to do at this time. You do not need to use an alternative (e.g., bottled) water supply.

What happened? Who is at risk? What is being done?

Notice of Violation / 2019 - 7209306 CHLORINE 0999 Our system received a Notice of Violation (NOV) from our primacy agency, Kentucky Division of Water. **Description of Non Compliance:** 401 KAR 8:020 & 8:150 CHLORINE The public water system failed to report on the MOR an adequate number of results for disinfectant residual in the distribution system for the compliance period 03/01/2019 - 03/31/2019. **Comments:** SDRD: Failed to collect and report minimum chlorine residual samples throughout the distribution system (MOR pg.7) for the monitoring period 03/01/2019 - 03/31/2019. **Remedial Measures:** Submit the MOR, if available, to the Division of Water within (30) days of receipt of this Notice of Violation. Perform Public Notification and the required Certification. Detail this NOV in the 2018 Consumer Confidence Report. Our system submitted the CHLORINE DATA in question. There were no health effects due to this NOV.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.