

## **Earlington Water and Sewer 2019 Water Quality Report**

Manager: Mark C. Pharris

CCR Contact: Mark C. Pharris

PWSID: KY0540108

Address: 103 West Main Street Earlington, Ky 42140

Phone: (270)383-5364

Meetings: 103 West Main Street / 2nd Tuesday, Monthly, at 6 PM

We purchase our water from the South Hopkins Water District which is purchased from Dawson Springs Water System. Their source is Lake Beshears which is classified as surface water. Sources of impact include chemical storage facilities, landfills, underground storage tanks, auto repair shops, oil/gas wells highways, bridges, waste water treatment plants, golf courses, cemeteries, septic systems, and agricultural. An analysis of the overall susceptibility is generally moderate for Lake Beshears. This is a summary of an assessment. The complete report is available at the Pennyrite Area Development office in Hopkinsville, located at 300 Hammond Drive Hopkinsville, Kentucky 42240. (270) 886-9484. It can also be obtained at Earlington City Hall 103 West Main Street, Earlington Kentucky 42410, (270) 383-5364. Also available at Kentucky Division of Water, 200 Fair Oaks Lane, 4th Floor, Frankfort, KY 40601, (502) 564-3410

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### **Some or all of these definitions may be found in this report:**

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

**To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.**

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

**Regulated Contaminant Test Results Dawson Springs Water and Sewer --- South Hopkins Water District**

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
<b>Inorganic Contaminants</b>									
Barium [1010] (ppm)	2	2	0.016	0.016	to	0.016	Feb-19	No	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.40	0.4	to	0.4	Feb-19	No	Water additive which promotes strong teeth

<b>Disinfection Byproduct Precursor</b>									
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.73 (lowest average)	1.19	to	2.07	2019	No	Naturally present in environment.

\*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

<b>Other Constituents</b>								
Turbidity (NTU) TT	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity		
* Representative samples Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.27	100	No	Soil runoff		

**Regulated Contaminant Test Results Earlington Water and Sewer**

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
<b>Disinfectants/Disinfection Byproducts and Precursors</b>									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	0.78 (highest average)	0.41	to	1.39	2019	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	47 (high site average)	11	to	47	2019	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	59 (high site average)	34	to	55	2019	No	Byproduct of drinking water disinfection.

<b>Household Plumbing Contaminants</b>									
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.117 (90 <sup>th</sup> percentile)	0	to	0.12	Aug-18	No	Corrosion of household plumbing systems

Violation #	Contaminant	Compliance Period	Explanation
2020-9952663	Failure to Submit MOR	10/01/2019 - 10/31/2019	Monthly Operating Reports (MOR) are to be received by the DOW no later than the 10th day after the compliance period. In October of 2019, we did not meet this requirement. The report was received by DOW two days late.
2020-9952664	Failure/ Chlorine Residual	10/01/2019 - 10/31/2019	By delivering the Monthly Operating Report (MOR) to the DOW past the due date, we received a violation for Failing to take the required Chlorine (CL2) Residual Samples because the CL2 samples are located within the MOR. All samples were taken in a timely manner.

This report will not be mail to each individual customer. A copy of this report is available at our office, located at 103 West Main Street, Earlington, Ky 42140. If you have any questions regarding this report, please contact Mark Pharris at (270)383-5364.