

# Brooksville Utility

## Water Quality Report 2021

Water System ID: KY0120044 Manager: Jeff Mofford 606-735-2501	CCR Contact: Jeff Mofford 606-735-2501 jmofford@windstream.net	Mailing Address: P.O. Box 216 Brooksville, KY 41004	Meeting location and time: Brooksville City Hall 2nd Thursday monthly at 6:30 PM
---	--	---	--

Brooksville Utility purchases water from Augusta Regional Water Treatment Plant and Western Mason Water District. The source of Augusta's drinking water is ground water from wells. The area around the wells is mostly residential but also contains some agricultural, recreational, and light industry activities and has a moderate susceptibility. The final source water assessment for our system has been completed and is contained in the Bracken County Water Supply Plan. The plan indicates that the source water is susceptible to some contaminants caused by agricultural activities in the area. The Plan is available for inspection at the Buffalo Trace Area Development District office. The Western Mason Water District withdraws groundwater from its wellfield located within the city limits of the City of Dover. The wellfield withdraws water from the Ohio River Alluvium, which is an unconfined aquifer consisting primarily of gravel and sand. A Wellhead Protection Plan has been developed for the Western Mason Water District to determine the susceptibility to potential sources of contamination to our wells. The plan indicates that this susceptibility is high with the possible sources of contamination being improper septic systems, agricultural activities, abandoned water wells, and transportation corridors. The complete Wellhead Protection Plan is available for review at the Western Mason Water District office during normal business hours.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Some or all of these definitions may be found in this report:

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, ( $\mu\text{g/L}$ ). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

### Regulated Contaminant Test Results for Brooksville Utility

Regulated Contaminant Test Results								Brooksville Utility	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.05 (highest average)	0.69 to 1.3	2021	No	Water additive used to control microbes.		
HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample)	60	N/A	11 (high site)	8 to 11 (range of individual sites)	2021	No	Byproduct of drinking water disinfection		
TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample)	80	N/A	36 (high site)	32 to 36 (range of individual sites)	2021	No	Byproduct of drinking water disinfection.		
Household Plumbing Contaminants									
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.133 (90th percentile)	0.039 to 0.139	Jun-21	No	Corrosion of household plumbing systems		
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	1 (90th percentile)	0 to 2	Jun-21	No	Corrosion of household plumbing systems		

### Regulated Contaminant Test Results for Augusta Regional

Regulated Contaminant Test Results								Augusta Regional Water	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
Radioactive Contaminants									
Combined radium (pCi/L)	5	0	0.203	0.203 to 0.203	May-20	No	Erosion of natural deposits		
Inorganic Contaminants									
Barium [1010] (ppm)	2	2	0.047	0.047 to 0.047	Apr-20	No	Drilling wastes; metal refineries; erosion of natural deposits		
Fluoride [1025] (ppm)	4	4	0.88	0.88 to 0.88	Apr-20	No	Water additive which promotes strong teeth		
Nitrate [1040] (ppm)	10	10	0.604	0.604 to 0.604	Mar-21	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits		
Other Constituents									
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity			
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.406	99	No	Soil runoff			

### Regulated Contaminant Test Results for Western Mason

Regulated Contaminant Test Results								Western Mason Water District	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
Inorganic Contaminants									
Barium [1010] (ppm)	2	2	0.042	0.042 to 0.042	Apr-20	No	Drilling wastes; metal refineries; erosion of natural deposits		
Fluoride [1025] (ppm)	4	4	0.57	0.57 to 0.57	Apr-20	No	Water additive which promotes strong teeth		
Nitrate [1040] (ppm)	10	10	5.28	4.38 to 5.28	Mar-21	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits		
Nitrite [1041] (ppm)	1	1	0.01	0 to 0.01	Mar-21	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits		

This report will not be mailed unless requested. Copies are available at our office. If you would like a copy mailed to you, please contact our office.