

Manager: Peter R. Conrad

Contact: Peter R. Conrad

Phone: (270)826-9802

Address: PO Box 655

Henderson KY 42419

Meetings: 655 South Main Street, Henderson KY 42420

Public Meetings 4th Wednesday of the month, 6:30 P.M.

Henderson County Water District (HCWD) purchases water from the Henderson Water Utility (HWU). HWU treats surface water from the Ohio and Green Rivers. Rivers are classified as surface water. The areas around your water sources are mostly residential but also contains some industrial activity. The final source water assessment for this system has been completed and is contained in the Henderson County Water Supply Plan. The plan is available for inspection at HWU, the GRADD office in Owensboro, Ky or from HCWD. An analysis of the susceptibility of Henderson's Ohio River and Green River water supplies to contamination indicates that this susceptibility is generally moderate. However, there are areas of high concern. Potential contaminant sources of concern include bridges, waste generators, transporters, landfills, railroad, row crop land, urban and recreational grass coverage, and sewer lines. Each of these are rated as high in a susceptibility because of the contaminant type, proximity to the intakes, and chance of release.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/L). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Copies of this report are available upon request by contacting our office during business hours.

Regulated Contaminant Test Results - Henderson Water Utility - North Plant and South Plant								
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Barium [1010] (ppm)	2	2	N S	0.027 0.024	0.027 to 0.027 0.024 to 0.024	2022	No	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	N S	0.6 0.63	0.6 to 0.6 0.63 to 0.63	2022	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	N S	0.993 1.08	0.993 to 0.993 1.08 to 1.08	2022	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants/Disinfection Byproducts and Precursors								
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	N S	1.63 2.16	1.32 to 2.56 1.29 to 2.88	2022	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.								
Chlorite (ppm)	1	0.8	N S	0.410 0.37	0 to 0.44 0.02 to 0.5	2022	No	Byproduct of drinking water disinfection.
Chlorine dioxide (ppb)	MRDL = 800	MRDLG = 800	N S	490 540	0 to 490 0 to 540	2022	No	Water additive used to control microbes.
Other Constituents								
Turbidity (NTU) TT * Representative samples	Allowable Levels		Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity	
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU Less than 0.3 NTU in 95% monthly samples		N S	0.086 0.854	100	No	Soil runoff	
Fluoride (added for dental health)				Average	Range of Detection			
			N	0.7	0.58 to 0.85			
			S	0.8	0.66 to 0.99			

Regulated Contaminant Test Results Henderson County Water District								
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination	
Disinfectants/Disinfection Byproducts and Precursors								
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.47 (highest average)	0.71 to 2.1	2022	No	Water additive used to control microbes.	
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	39 (high site average)	14 to 63 (range of individual sites)	2022	No	Byproduct of drinking water disinfection	
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	59 (high site average)	19 to 65 (range of individual sites)	2022	No	Byproduct of drinking water disinfection.	
Household Plumbing Contaminants								
Copper [1022] (ppm) Round sites exceeding action level 0	AL = 1.3	1.3	0.073 (90 th percentile)	0.007 to 0.203	Aug-21	No	Corrosion of household plumbing systems	

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

During the past year we were required to conduct one Level 1 assessment. One Level 1 assessment was completed. In addition, we were required to take two corrective actions and we completed two of these actions.

Violation 2022 – 20

Our Water Quality Report (CCR) for last year contained some errors that resulted in a violation. Listed below are the errors and remedial actions.

1. The HAA and TTHM results were reported in ppm but labeled as ppb. The correct values should have been for HAA an average of 38 ppb with a range of 24 ppb to 50 ppb and for TTHM the average should have been 58 ppb with a range of 31 ppb to 80 ppb.
2. The 90th percentile value of 0.073 was not included. That value is included in this year's report.
3. The link submitted on the CCR certification form was incorrect. The correct link to our CCR is tapwaterinfo.com/henderson