

Peaks Mill Water District Water Quality Report 2022

Water System ID: KY0370346
Manager: Jeff Lee
502-227-5740

CCR Contact: Nancy Sherrow
502-227-5740
pmwd2011@att.net

Mailing Address:
7165 US 127 North
Frankfort, KY 40601

Meeting location and time:
Peaks Mill Water District office
2nd Monday monthly at 5:30 PM

Peaks Mill purchases water from the City of Frankfort and Kentucky American Water Company (KAWC). Both suppliers treat surface water from the Kentucky River. KAWC also treats surface water from Jacobson Reservoir. An analysis of the susceptibility to contamination of the water sources indicates that the susceptibility is rated as moderate to high. Areas of concern include transportation corridors where accidental spills could pose an immediate threat to the intakes. Other areas of concern include hazardous waste generators and/or transporters, contamination from agricultural runoff, urban storm water runoff, industrial and construction runoff, a Superfund site, sewer lines and KPDES permitted dischargers, underground storage tanks, and power line rights-of-way. The complete Source Water Assessment Plans are available for review at the respective water suppliers at the Frankfort Plant Board Water Treatment Plant or the KAWC Customer Service Center at (800) 678-6301.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, ($\mu\text{g/L}$). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variance & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

This report will not be mailed unless requested. Copies are available at our office. If you would like a copy mailed to you please contact our office.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

Regulated Contaminant Test Results Peaks Mill Water District							
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Disinfectants/Disinfection Byproducts and Precursors							
Chloramines (ppm)	MRDL = 4	MRDLG = 4	2.22 (highest average)	0.02 to 3.37	2022	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	33 (high site average)	15 to 46 (range of individual sites)	2022	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	35 (high site average)	14.8 to 39.2 (range of individual sites)	2022	No	Byproduct of drinking water disinfection.
Household Plumbing Contaminants							
Copper [1022] (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.31 (90 th percentile)	0 to 0.65	Aug-21	No	Corrosion of household plumbing systems
Lead [1030] (ppb) Round 1 sites exceeding action level 0	AL = 15	0	0 (90 th percentile)	0 to 2.1	Aug-21	No	Corrosion of household plumbing systems

Violation ID 2023-879

Our water system failed to comply with required testing procedures. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 3rd quarter of 2022 (July 1, 2022 – September 30, 2022) we failed to sample for Disinfection By-Products (Haloacetic Acids & Trihalomethanes) during our peak historical month which is the second week of August. Therefore, we could not verify the quality of your drinking water to the primacy agency during that time.

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We are required to collect Disinfection By-Products once per quarter and failed to do so in the proper week of the month of August. We sampled in September once we knew of the error and are in compliance.

For more information, please contact Jeff Lee at 502-227-5740 or 7165 US 127 North Frankfort, KY 40601.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Regulated Contaminant Test Results Frankfort Plant Board (F) Kentucky American Water (K)								
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Inorganic Contaminants								
Barium [1010] (ppm)	2	2	F=	0.017	0.017 to 0.017	2022	No	Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	F=	0.60	0.60 to 0.60	2022	No	Water additive which promotes strong teeth
			K=	0.74	0.74 to 0.74	2022	No	
Nickel (ppb) (US EPA remanded MCL in February 1995.)	N/A	N/A	A=	1	1 to 1	2022	No	N/A
Nitrate [1040] (ppm)	10	10	F=	0.396	0.236 to 0.396	2022	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
			K=	0.75	0.75 to 0.75	2022	No	
Disinfectants/Disinfection Byproducts and Precursors								
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	F=	1.61	1.24 to 2.20	2022	No	Naturally present in environment.
			K=	1.82	1.17 to 2.94	2022	No	

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Other Constituents							
Turbidity (NTU) TT	Allowable Levels	Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity	
* Representative samples	No more than 1 NTU* Less than 0.3 NTU in 95% monthly samples	F=	0.19	100	No	Soil runoff	
Turbidity is a measure of the clarity of the water and not a contaminant.		K=	0.07	100	No		