

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, ($\mu\text{g/L}$). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.



To request a paper copy call (606)287-8305.



Water System ID: KY0550784

Manager: J. Michael Stidham

606-287-8305

CCR Contact: J. Michael Stidham

606-287-8305

Mailing address:

P.O. Box 455

McKee, KY 40447

Meeting location and time:

McKee City Hall

Third Monday each month at 6:00 PM

Water Produced by McKee Water Works

The City of McKee Water Works treated surface water from the McKee Reservoir. An analysis of the susceptibility of the McKee water supply to contamination indicates that this susceptibility is borderline. The largest potential contaminant threat immediately upstream of the intake is land coverage. The predominant land cover is forest; this land cover could be subject to logging which may result in soil erosion if Best Management Practices (BMPs) are not carefully applied. The complete Source Water Assessment Plan can be reviewed at our water system office during normal business hours. We now purchase water from Jackson Co. Water Association which treats surface water from Lake Beulah. There are roadway bridges and a railroad located within the watersheds. Other activities of concern include wastewater discharges, Tier II hazardous chemical users, waste generators or transporters, underground storage tanks and injection control wells. Under certain circumstances activities within the watershed could release contaminants and thereby pose potential risks to your drinking water. These activities, and how they are conducted, are of interest to the entire community because they potentially affect your health and the cost of treating your water. The complete source water assessment plan for Jackson County may be reviewed at the Cumberland Valley Area Development District in London,.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses).

Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

Regulated Contaminant Test Results McKee Water Works

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------------	--------------------	----------------	-----------	--------------------------------

Inorganic Contaminants

Fluoride [1025] (ppm)	4	4	0.92	0.92 to 0.92	May-23	No	Water additive which promotes strong teeth
-----------------------	---	---	------	--------------	--------	----	--

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.52 (lowest average)	1.33 to 1.69 (monthly ratios)	2023	No	Naturally present in environment.
---	-----	-----	-----------------------	-------------------------------	------	----	-----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.46 (highest average)	0.63 to 2.09	2023	No	Water additive used to control microbes.
----------------	----------	-----------	------------------------	--------------	------	----	--

HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	66 (high site average)	4 to 89 (range of individual sites)	2023	YES	Byproduct of drinking water disinfection
--	----	-----	------------------------	-------------------------------------	------	-----	--

TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	72 (high site average)	32.6 to 96.6 (range of individual sites)	2023	No	Byproduct of drinking water disinfection.
--	----	-----	------------------------	--	------	----	---

Household Plumbing Contaminants

Copper [1022] (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.036 (90 th percentile)	0 to 0.237	Sep-23	No	Corrosion of household plumbing systems
--	----------	-----	-------------------------------------	------------	--------	----	---

Lead [1030] (ppb) Round 1 sites exceeding action level 0	AL = 15	0	0 (90 th percentile)	0 to 2	Sep-23	No	Corrosion of household plumbing systems
--	---------	---	---------------------------------	--------	--------	----	---

Other Constituents

Turbidity (NTU) TT * Representative samples	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
---	------------------	----------------------------	------------------	-----------	----------------------------

Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.26	100	No	Soil runoff
---	--	------	-----	----	-------------

Violation ID 2023-8916515

Testing results from 4/1/2023 to 6/30/2023 show that our system exceeds the standard, or maximum contaminant level (MCL), for haloacetic acids (HAA). The standard for HAA is 0.060 mg/L. It is determined by averaging all samples collected at each sampling location for the last 12 months. The level of HAA averaged at one of our system's locations for 4/1/2023 to 6/30/2023 was 0.066 mg/L.

Violation ID 2024-8916512

Testing results from 7/1/2023 to 9/30/2023 show that our system exceeds the standard, or maximum contaminant level (MCL), for haloacetic acids (HAA). The standard for HAA is 0.060 mg/L. It is determined by averaging all samples collected at each sampling location for the last 12 months. The level of HAA averaged at one of our system's locations for 7/1/2023 to 9/30/2023 was 0.065 mg/L.

Regulated Contaminant Test Results Jackson Co. Water Association

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------------	--------------------	----------------	-----------	--------------------------------

Radioactive Contaminants

Combined radium (pCi/L)	5	0	0.577	0.577 to 0.577	2019	No	Erosion of natural deposits
-------------------------	---	---	-------	----------------	------	----	-----------------------------

Inorganic Contaminants

Barium [1010] (ppm)	2	2	0.011	0.011 to 0.011	2023	No	Drilling wastes; metal refineries; erosion of natural deposits
---------------------	---	---	-------	----------------	------	----	--

Fluoride [1025] (ppm)	4	4	0.070	0.070 to 0.070	2023	No	Water additive which promotes strong teeth
-----------------------	---	---	-------	----------------	------	----	--

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.65 (lowest average)	1.00 to 2.43 (monthly ratios)	2023	No	Naturally present in environment.
---	-----	-----	-----------------------	-------------------------------	------	----	-----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

Other Constituents

Turbidity (NTU) TT * Representative samples	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
---	------------------	----------------------------	------------------	-----------	----------------------------

Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.1	100	No	Soil runoff
---	--	-----	-----	----	-------------