

# Bullock Pen Water District

## Water Quality Report 2023

Water System ID: KY0410047  
Superintendent: Paul Harp  
859-428-2112

CCR Contact: Amy Ruark  
859-428-2112  
aruark@bpwd.org

Mailing Address:  
P.O. Box 188  
Crittenden, KY 41030

Meeting location and time:  
1 Farrell Drive, Crittenden, KY  
3<sup>rd</sup> Thursday, monthly at 1PM

### Source Information:

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide our customers with a safe, clean and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system.

Our water source is surface water withdrawn from the following water bodies: Ohio River, Licking River, Bullock Pen Lake, and Williamstown Lake. We process water from Bullock Pen Lake at our treatment plant and purchase water from Boone County Water District, supplied by Greater Cincinnati Water Works (Ohio River); Walton Water Works, supplied by Northern Kentucky Water District (Ohio and Licking Rivers); Northern Kentucky Water District (Ohio and Licking Rivers) and City of Williamstown (Williamstown Lake). A susceptibility analysis for each source has been completed. The susceptibility to contamination of the Ohio and Licking Rivers is high whereas Bullock Pen and Williamstown Lake is moderate. Several areas of concern are related to the extensive development of transportation infrastructure, the potential for spills, high degree of impervious cover and polluted runoff. Areas of row crops and urban and recreational grasses introduce the potential for herbicide, pesticide, and fertilizer use. Bridges, railroads, ports, waste handlers or generators, and Tier II hazardous chemical users in the area introduce the potential for spills or leaks of hazardous materials. The completed report is available for inspection at the Northern Kentucky Area Development District.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

### Some or all of these definitions may be found in this report:

**Level 1 Assessment** – A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in the water system.

**Level 2 Assessment** – A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, ( $\mu\text{g/L}$ ). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

**To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.**

**B=Bullock Pen C=Greater Cincinnati Water Works N=Northern Kentucky WD W=City of Williamstown**

<b>Regulated Contaminant Test Results</b>									
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination	
<b>Inorganic Contaminants</b>									
Barium [1010] (ppm)	2	2	B= W= N= C=	0.013 0.009 0.026 0.03	0.013 to 0.013 0.009 to 0.009 0.022 to 0.03 0.03 to 0.03	2023 2023 2023 2023	No No No No	Drilling wastes; metal refineries; erosion of natural deposits	
Fluoride [1025] (ppm)	4	4	B= W= N= C=	0.88 0.73 0.77 0.86	0.88 to 0.88 0.73 to 0.73 0.71 to 0.82 0.73 to 1	2023 2023 2023 2023	No No No No	Water additive which promotes strong teeth	
Nickel (ppb) (US EPA remanded MCL in February 1995.)	N/A	N/A	B=	3	3 to 3	2023	No	N/A	
Nitrate [1040] (ppm)	10	10	B= C= N=	0.732 1.15 0.53	0.732 to 0.732 0.56 to 1.15 0.17 to 0.53	2023 2023 2023	No No No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits	
<b>Disinfectants/Disinfection Byproducts and Precursors</b>									
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	B= W= N= C=	1.34 1.15 2.12 2.38	1.04 to 1.96 0.88 to 1.37 1.13 to 3.12 2.06 to 3.26	2023 2023 2023 2023	No No No No	Naturally present in environment.	
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	B=	1.03 (highest average)	0.62 to 1.72	2023	No	Water additive used to control microbes.	
Chlorite (ppm)	1	0.8	W=	0.590 (average)	0.33 to 0.68	2023	No	Byproduct of drinking water disinfection.	
Chlorine dioxide (ppb)	MRDL = 800	MRDLG = 800	W=	650	0 to 650	2023	No	Water additive used to control microbes.	
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	B=	36 (average)	2 to 52 (range of individual sites)	2023	No	Byproduct of drinking water disinfection	
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	B=	43 (average)	18.8 to 65.4 (range of individual sites)	2023	No	Byproduct of drinking water disinfection.	
<b>Household Plumbing Contaminants</b>									
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	B=	0.264 (90 <sup>th</sup> percentile)	0.0039 to 0.5434	2022	No	Corrosion of household plumbing systems	
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	B=	2.9 (90 <sup>th</sup> percentile)	0 to 7	2022	No	Corrosion of household plumbing systems	
<b>Other Constituents</b>									
Turbidity (NTU) TT * Representative samples	<b>Allowable Levels</b>		Source	<b>Highest Single Measurement</b>	<b>Lowest Monthly %</b>	<b>Violation</b>	<b>Likely Source of Turbidity</b>		
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% monthly samples		B= W= N= C=	0.098 0.08 0.05 0.09	100 100 100 100	No No No No	Soil runoff		

Unregulated Contaminants (UCMR 5)		average	range (ppb)		date
perfluoropentanoic acid (PFPeA)	N=	0.0031	0	to 0.0031	2023

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. Water supplied by Greater Cincinnati Water Works and the City of Williamstown was tested in 2023, and none of the unregulated contaminants were detected. Water supplied by Northern Kentucky Water District was tested in 2023 and 1 of the 29 unregulated contaminants was detected (data in table above). If you are interested in examining the results, please contact our office during normal business hours.



Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

**This report will not be mailed. If you would like to receive a copy by mail, please contact our office.**