

# Garrison Quincy Water District

## Water Quality Report 2023

Water System ID: KY0680153 Manager: Trent Underwood 606-757-4898	CCR Contact: Trent Underwood 606-757-4898 garrisonwater@windstream.net	Mailing Address: P.O. Box 279 Garrison, KY 41141	Meeting location and time: Water Plant Office 2nd Tuesdays, monthly at 3PM
--	--	--	--

The source of your drinking water comes from three groundwater wells. Our water treatment plant treats 90% of the water for our service area. The remaining 10% is purchased wholesale from the City of Vanceburg and serves our customers on Kinney Road. Vanceburg's water source is from four groundwater wells. Both Garrison and Vanceburg routinely monitor for contaminants in your drinking water according to Federal and State laws. The area around the wells is mostly residential but also contains some agricultural, recreational, and light industry activities. The final source water assessment for our system has been completed. Copies of the plan are available at our office at 284 Murphys Lane in Garrison, KY. An analysis of the overall susceptibility to contamination of the Garrison Quincy Heights Water District's water supply indicated that its susceptibility is moderate.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

### Some or all of these definitions may be found in this report:

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, ( $\mu\text{g/L}$ ). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

**To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.**

**Testing Results from Vanceburg Water**

Regulated Contaminant Test Results		City of Vanceburg Electric Plant Board							
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
<b>Inorganic Contaminants</b>									
Barium [1010] (ppm)	2	2	0.059	0.059	to	0.059	21-Aug	No	Drilling wastes; metal refineries; erosion of natural deposits
Chromium [1020] (ppb)	100	100	0.5	0.5	to	0.5	21-Aug	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.8	0.79	to	0.8	23-Mar	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	2.72	2.72	to	2.72	23-Sep	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits

**Testing Results from Garrison-Quincy Water District**

Regulated Contaminant Test Results		Garrison Quincy Water District							
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
<b>Radioactive Contaminants</b>									
Uranium (µg/L)	30	0	2.07	2.07	to	2.07	Nov-19	No	Erosion of natural deposits
<b>Inorganic Contaminants</b>									
Fluoride [1025] (ppm)	4	4	0.99	0.99	to	0.99	May-23	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	1.79	1.79	to	1.79	Sep-23	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfectants/Disinfection Byproducts and Precursors</b>									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	0.94 (highest average)	0.72	to	1.18	2023	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample)	60	N/A	1 (high site)	1	to	1 (range of individual sites)	2023	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample)	80	N/A	8 (high site)	7	to	8 (range of individual sites)	2023	No	Byproduct of drinking water disinfection.
<b>Household Plumbing Contaminants</b>									
Copper [1022] (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.744 (90 <sup>th</sup> percentile)	0.023	to	0.753	Jul-21	No	Corrosion of household plumbing systems

	Average	Range of Detection
Fluoride (added for dental health)	0.8	0.72 to 0.94
Sodium (EPA guidance level = 20 mg/L)	23.9	23.88 to 23.88

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

**This report will not be mailed unless requested. Additional copies will be available at the Water District Office during normal business hours. Please call our office if you have any questions.**