

City of Guthrie
Water Quality Report
2023

PWSID ID: KY1100171
 Manager: Benn Andrew Stahl
 (270) 483-2511
 CCR Contact: Benn Stahl
 (270) 483-2511
guthriecityutilities@outlook.com

Mailing address:
 P.O. Box 125
 Guthrie, Ky 42234

Meeting location and time:
 110 Kendall Street,
 Trenton, KY 42286
 Second Tuesday of each month
 at 7:00 PM

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high-quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.



Cryptosporidium

Cryptosporidium is a microbial parasite found in surface water throughout the U.S. Although filtration removes Cryptosporidium, 100 percent removal cannot be guaranteed. Our monitoring indicated the presence of one of these organisms in our source water. Current test methods do not allow us to determine if the organism is dead or alive or if it was capable of causing disease. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy individuals are able to overcome the disease within a few weeks. However, immune-compromised people have more difficulty and are at greater risk of developing severe, life threatening illness. Cryptosporidium must be ingested for it to cause disease, and may be passed through means other than drinking water.

Type and Location of Source Water

The City of Guthrie Water System purchases water from the Logan/Todd Regional Water Commission (LTRWC), which produces treated drinking water at the George W. Arnold Treatment Plant. The raw water intake is surface water located in the main channel of the Cumberland River, in Clarksville, Montgomery County, Tennessee. The protection area taken into consideration is from the LTRWC intake point to the Clarksville Water System intake upstream. Urban nonpoint source runoff may contribute contamination to the water supply by delivering sediment, oil and grease, road salt, fertilizers, pesticides, nutrients, and other contaminants to the Cumberland River. Transportation corridors pose a significant threat to water quality. Transportation accidents can release substances into water supplies, threatening water quality. Tractor-trailers, barges, rail cars and pipelines all have the potential for adverse impact of our water supply. A state primary road – TN 13 – crosses the Cumberland River, as do the Cunningham Bridge and the L&N Railroad Bridge. Water sources have been rated as reasonably susceptible (high), moderately susceptible (moderate) or slightly susceptible (low) based on geologic factors and human activities in the vicinity of the water source. The water source for LTRWC is rated as reasonably susceptible to potential contamination. For more information regarding the LTRWC source water protection area and plan, contact LTRWC located at 248 Tower Street in Guthrie, Kentucky.

Information About Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and [components](#) associated with service lines and home plumbing. The City of Trenton is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing [components](#) in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Trenton Water and Sewer at 270-466-3332. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>

- Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*
- Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*
- Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.*
- Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.*
- Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.*
- Not Applicable (N/A) - does not apply.*
- Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.*
- Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.*
- Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.*
- Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.*
- Picocuries per liter (pCi/L) - a measure of the radioactivity in water.*
- Millirems per year (mrem/yr) - measure of radiation absorbed by the body.*
- Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.*
- Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.*
- Variances & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.*
- Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.*
- Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.*

City of Guthrie 2023 Water Quality Data

KY1100171

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	0.077	100	No	Soil runoff

Regulated Contaminant Test Results

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------------	--------------------	----------------	-----------	--------------------------------

Inorganic Contaminants

Barium [1010] (ppm)	2	2	0.0239	0.0239 to 0.0239	Jun-23	No	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.074 (90 th percentile)	0.014 to 0.106	Aug-23	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	0.804	0.804 to 0.804	Jun-23	No	Water additive which promotes strong teeth
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	3 (90 th percentile)	2 to 4	Aug-23	No	Corrosion of household plumbing systems
Nitrate [1040] (ppm)	10	10	0.321	0.321 to 0.321	Feb-23	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.79 (lowest average)	1.67 to 1.85 (monthly ratios)	2023	No	Naturally present in environment.
---	-----	-----	-----------------------	-------------------------------	------	----	-----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample)	80	N/A	37 (high site)	18 to 44 (range of individual sites)	2023	No	Byproduct of drinking water disinfection.
HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample)	60	N/A	28 (high site)	11 to 24 (range of individual sites)	2023	No	Byproduct of drinking water disinfection
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.80 (highest average)	0.55 to 3.4	2023	No	Water additive used to control microbes.

The City of Guthrie sampled for Chlorine, Lead, Copper, HAA and TTHM. All other parameters were completed by LTRWC.