

# *Sandy Hook Water District*

## *Water Quality Report 2023*

|  |  |  |   |
|--|--|--|---|
| Water System ID: KY0320383<br>Manager: Jessica Litton-Adkins<br>606-738-6282 | CCR Contact: Joe Adkins<br>606-738-6282<br>shwaterdistrict@outlook.com | Mailing Address:<br>P.O. Box 726<br>Sandy Hook, KY 41171 | Meeting location and time:<br>474 Howards Creek Road<br>2nd Thursday, monthly at 1 PM |
|--|--|--|---|

The Sandy Hook Water District withdraws, treats, and distributes groundwater from wells drilled into the Lee Sandstone. We have completed a Wellhead Protection Plan which was approved by the Kentucky Division of Water in 2000. Part of this plan includes a source water assessment. This assessment includes a susceptibility analysis to determine the risk of contamination to our water supply from various land uses. The susceptibility is based on several factors such as well depth and type of aquifer, the proximity of the contaminant sources to the well or well field, and the nature of the potential contaminant source. Overall, the susceptibility rating for our source is moderate due to the potential sources from agricultural land use and septic systems. Under certain circumstances contaminants could be released that would pose challenges for water treatment, or even get into your drinking water. The Wellhead Protection Plan can be reviewed at our office.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### **Information About Lead:**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

### **Some or all of these definitions may be found in this report:**

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, ( $\mu\text{g/L}$ ). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

**To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.**

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

**Regulated Contaminant Test Results Sandy Hook Water District**

| Contaminant [code] (units) | MCL | MCLG | Report Level | Range of Detection | Date of Sample | Violation | Likely Source of Contamination |
|----------------------------|-----|------|--------------|--------------------|----------------|-----------|--------------------------------|
|----------------------------|-----|------|--------------|--------------------|----------------|-----------|--------------------------------|

**Radioactive Contaminants**

|                         |   |   |      |              |        |    |                             |
|-------------------------|---|---|------|--------------|--------|----|-----------------------------|
| Combined radium (pCi/L) | 5 | 0 | 2.63 | 2.63 to 2.63 | May-20 | No | Erosion of natural deposits |
|-------------------------|---|---|------|--------------|--------|----|-----------------------------|

**Inorganic Contaminants**

|                     |   |   |       |                |        |    |  |
|---------------------|---|---|-------|----------------|--------|----|--|
| Barium [1010] (ppm) | 2 | 2 | 0.345 | 0.345 to 0.345 | May-21 | No | Drilling wastes; metal refineries; erosion of natural deposits |
|---------------------|---|---|-------|----------------|--------|----|--|

|                       |   |   |      |              |        |    |  |
|-----------------------|---|---|------|--------------|--------|----|--|
| Fluoride [1025] (ppm) | 4 | 4 | 0.85 | 0.85 to 0.85 | May-21 | No | Water additive which promotes strong teeth |
|-----------------------|---|---|------|--------------|--------|----|--|

**Disinfectants/Disinfection Byproducts and Precursors**

|                |          |           |                        |              |      |    |  |
|----------------|----------|-----------|------------------------|--------------|------|----|--|
| Chlorine (ppm) | MRDL = 4 | MRDLG = 4 | 1.21 (highest average) | 0.87 to 1.47 | 2023 | No | Water additive used to control microbes. |
|----------------|----------|-----------|------------------------|--------------|------|----|--|

|  |    |     |                |                                     |      |     |  |
|--|----|-----|----------------|-------------------------------------|------|-----|--|
| HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample) | 60 | N/A | 86 (high site) | 9 to 86 (range of individual sites) | 2023 | No* | Byproduct of drinking water disinfection |
|--|----|-----|----------------|-------------------------------------|------|-----|--|

|  |    |     |                |                                      |      |    |   |
|--|----|-----|----------------|--------------------------------------|------|----|---|
| TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample) | 80 | N/A | 74 (high site) | 20 to 74 (range of individual sites) | 2023 | No | Byproduct of drinking water disinfection. |
|--|----|-----|----------------|--------------------------------------|------|----|---|

*\*Annual Stage 2 sample triggered quarterly sampling. No violation if only the annual sample exceeded the MCL.*

**Household Plumbing Contaminants**

|  |          |     |                                     |                |        |    |   |
|--|----------|-----|-------------------------------------|----------------|--------|----|---|
| Copper [1022] (ppm) Round 1 sites exceeding action level 0 | AL = 1.3 | 1.3 | 0.924 (90 <sup>th</sup> percentile) | 0.028 to 1.031 | Sep-23 | No | Corrosion of household plumbing systems |
|--|----------|-----|-------------------------------------|----------------|--------|----|---|

|  |         |   |                                 |        |        |    |   |
|--|---------|---|---------------------------------|--------|--------|----|---|
| Lead [1030] (ppb) Round 1 sites exceeding action level 0 | AL = 15 | 0 | 0 (90 <sup>th</sup> percentile) | 0 to 2 | Sep-23 | No | Corrosion of household plumbing systems |
|--|---------|---|---------------------------------|--------|--------|----|---|

| Fluoride (added for dental health) | Average |     | Range of Detection |    |
|------------------------------------|---------|-----|--------------------|----|
|                                    |         | 0.8 | 0.58               | to |

| Secondary Contaminant  | Maximum Allowable Level | Report | Range        |    | Date of |        |
|------------------------|-------------------------|--------|--------------|----|---------|--------|
|                        |                         | Level  | of Detection |    | Sample  |        |
| Chloride               | 250 mg/l                | 17.9   | 17.9         | to | 17.9    | Mar-23 |
| Copper                 | 1.0 mg/l                | 0.04   | 0.04         | to | 0.04    | Mar-23 |
| Corrosivity            | Noncorrosive            | 0.75   | 0.75         | to | 0.75    | Mar-23 |
| Fluoride               | 2.0 mg/l                | 0.74   | 0.74         | to | 0.74    | Mar-23 |
| pH                     | 6.5 to 8.5              | 7.23   | 7.23         | to | 7.23    | Mar-23 |
| Sulfate                | 250 mg/l                | 7.6    | 7.6          | to | 7.6     | Mar-23 |
| Total Dissolved Solids | 500 mg/l                | 208    | 208          | to | 208     | Mar-23 |

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Your drinking water at Sandy Hook Water District has been sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours. None of the contaminants that were tested for were detected at this time.

**This report will not be mailed unless requested. Please call our office if you have any questions.**