

**Some or all of these definitions may be found in this report:**

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

**Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.**

# City of Cynthiana

## Water Quality Report for 2024

For previous reports include year.

Example: tapwaterinfo.com/2023/Cynthiana



Water System ID: KY0490096

Manager: Todd Blanton

(859) 234-7159

CCR Contact: Todd Blanton

todd.blanton@cynthianaky.com

Mailing address:

P.O. Box 67

Cynthiana, KY 41031

Meeting location and time:

Harrison County Board of Education

308 Webster Avenue

First and Third Tuesdays each month at 5:30 PM

### Source Information:

The City of Cynthiana's water source is surface water. We have two sources of water. The primary source is the South Fork of the Licking River, which begins in Bourbon County with the confluence of Hinkston and Stoner Creeks at Ruddles Mill. The second source is the Main Licking River at the Devils Backbone. We have completed a Source Water Assessment Plan (SWAP) and the following is a summary of our system's susceptibility to contamination. An analysis of the susceptibility of the Cynthiana water supply to contamination indicates that this susceptibility is generally moderate. There are, however, a few areas of high concern. Several bridges, a railroad, areas of row crops, sewer lines, several firms that treat, store or dispose of hazardous waste, a historical landfill, an airport, a KPDES permitted discharger, several waste generators and/or transporters and recreational grasses are present in the vicinity of the intakes. There are numerous permitted operations and activities and

other potential contaminant sources within the watersheds. These potential contaminant sources include underground storage tanks, forest areas, major roads and firms that handle hazardous wastes. The complete Source Water Assessment (SWAP) can be viewed at either the Water Treatment Plant, at 201 Waterworks/Abdallah Park Road, or the City Clerk's Office, at 141 East Pike Street, Suite One.

### Message from the EPA:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care

providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information about Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

We are required to annually provide information about the health risks from lead in drinking water to schools and child care facilities. All elementary schools, secondary schools, and child care facilities are eligible to be sampled for lead by our water system. Contact our office for scheduling or to learn results of previous sampling.

### Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials.

We have completed a service line inventory (SLI) and it is available for review online at:

<https://qrs.ly/dvgmk08>

You can also access the inventory by scanning this:



### Lead Sample Results Availability Information:

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at 0.015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at our office.

Regulated Contaminant Test Results								Cynthiana Municipal Water Works	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
<b>Radioactive Contaminants</b>									
Alpha emitters [4000] (pCi/L)	15	0	3.9	3.9 to 3.9	Apr-21	No	Erosion of natural deposits		
<b>Inorganic Contaminants</b>									
Barium [1010] (ppm)	2	2	0.02	0.02 to 0.02	Apr-24	No	Drilling wastes; metal refineries; erosion of natural deposits		
Fluoride [1025] (ppm)	4	4	0.75	0.75 to 0.75	Apr-24	No	Water additive which promotes strong teeth		
Nitrate [1040] (ppm)	10	10	0.6	0.6 to 0.6	Jun-24	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits		
<b>Synthetic Organic Contaminants including Pesticides and Herbicides</b>									
Atrazine [2050] (ppb)	3	3	BDL	BDL to 0.29	Jun-23	No	Runoff from herbicide used on row crops		
<b>Disinfectants/Disinfection Byproducts and Precursors</b>									
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.65 (lowest average)	0.92 to 3.40 (monthly ratios)	2024	No	Naturally present in environment.		
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.03 (highest average)	0.28 to 1.93	2024	No	Water additive used to control microbes.		
Chlorite (ppm)	1	0.8	0.90 (average)	0.49 to 0.93	2024	No	Byproduct of drinking water disinfection.		
Chlorine dioxide (ppb)	MRDL = 800	MRDLG = 800	400	0 to 400	2024	No	Water additive used to control microbes.		
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	41 (high site average)	18 to 76 (range of individual sites)	2024	No	Byproduct of drinking water disinfection		
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	55 (high site average)	9.9 to 54.6 (range of individual sites)	2024	No	Byproduct of drinking water disinfection.		
<b>Household Plumbing Contaminants</b>									
Copper (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.261 (90 <sup>th</sup> percentile)	0.015 to 0.296	Jul-23	No	Corrosion of household plumbing systems		
Lead (ppb) Round 1 sites exceeding action level 0	AL = 15	0	5 (90 <sup>th</sup> percentile)	0 to 11	Jul-23	No	Corrosion of household plumbing systems		
<b>Other Constituents</b>									
Turbidity (NTU) TT * Representative samples	<b>Allowable Levels</b>		<b>Highest Single Measurement</b>	<b>Lowest Monthly %</b>	<b>Violation</b>	<b>Likely Source of Turbidity</b>			
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.139	100	No	Soil runoff			

Fluoride (added for dental health)	Average		Range of Detection	
	0.7	0.6	to	0.96
Sodium (EPA guidance level = 20 mg/L)	7.6	7.6	to	7.6

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Secondary Contaminant	Maximum Allowable Level	Report Level	Range of Detection	Date of Sample
Aluminum	0.05 to 0.2 mg/l	0.08	0.08 to 0.08	Apr-24
Chloride	250 mg/l	14.18	14.18 to 14.18	Apr-24
Corrosivity	Noncorrosive	0.17	0.17 to 0.17	Apr-24
Fluoride	2.0 mg/l	0.75	0.75 to 0.75	Apr-24
pH	6.5 to 8.5	7.77	7.77 to 7.77	Apr-24
Sulfate	250 mg/l	15.72	15.72 to 15.72	Apr-24
Total Dissolved Solids	500 mg/l	200	200 to 200	Apr-24

Unregulated Contaminants (UCMR 5)	average	range (ppb)	date
perfluoroheptanoic acid (PFHpA)	0.001	0 to 0.0031	Jul-24
perfluorohexanesulfonic acid (PFHxS)	0.004	0 to 0.011	Jul-24
perfluorohexanoic acid (PFHxA)	0.001	0 to 0.0058	Jul-24
perfluorooctanesulfonic acid (PFOS)	0.015	0 to 0.037	Jul-24
perfluoropentanoic acid (PFPeA)	0.002	0 to 0.0071	Jul-24

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office.

