

# The City of Raceland Water Quality Report 2024

For previous reports include year.  
Example: [tapwaterinfo.com/2023/raceland](http://tapwaterinfo.com/2023/raceland)

Water System ID: KY0450365 Manager: Dustin Burchett 606-836-4522	CCR Contact: Dustin Burchett 606-836-4522	Mailing Address: 711 Chinn Street Raceland, KY 41169	Meeting location and time: Raceland City Hall 2 <sup>nd</sup> Tuesday, monthly at 6 PM
--	--	--	--

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

#### Source Information:

Our water comes from Russell and Flatwoods (who purchases water treated by Ashland). Both Russell and Ashland treat surface water from the Ohio River. A susceptibility analysis evaluates the potential for contaminants to enter the water supply by identifying potential contaminant sources and rating them by proximity to the system's intake, the likelihood of release for the contaminant type, and by the nature of the contaminant itself. Within the Kentucky portion of the protection zone, there are 536 identified potential contaminant sources. Of these 302 have a susceptibility rating of High, 206 rated Medium and 28 rated Low. Oil spills which receive a High rating may float by the intake without noticeable effect. Chemicals which mix with the water present a different kind of threat and the intake may be shut down until the danger passes. In all cases the Ohio River Valley Sanitation Commission (ORSANCO) issues notices of spills, their location on the river and the speed of the river. Given the number of High ranked potential contaminant sources, both water systems are ranked Moderately High in their source water assessments. The complete Source Water Assessment Plans for the respective water systems can be viewed at the Russell Water Company office or Ashland Water Works.

#### Service Area Information:

All customers are routinely served by the City of Russell. We have connections to Flatwoods (who purchases from Ashland), but that water is only used in case of emergency when Russell cannot supply us with water. No emergency purchases were made this year.

#### Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

We are required to annually provide information about the health risks from lead in drinking water to schools and child care facilities. All elementary schools, secondary schools, and child care facilities are eligible to be sampled for lead by our water system. Contact our office for scheduling or to learn results of previous sampling.

#### Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. We have completed a service line inventory (SLI) and it is available for review at our office or online at <https://qrs.ly/a7gmtex> (or by scanning the QR code to the right).



**Lead Sample Results Availability Information:**

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at 0.015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at our office.

**Some or all of these definitions may be found in this report:**

- Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.
- Not Applicable (N/A)** - does not apply.
- Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb)** - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
- Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.
- Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.
- Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.
- Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
- Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.
- Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office.

Regulated Contaminant Test Results			Raceland Water System				
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
<b>Disinfectants/Disinfection Byproducts and Precursors</b>							
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.30 (highest average)	0.43 to 2.03	2024	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	39 (high site average)	12 to 60 (range of individual sites)	2024	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	80 (high site average)	45 to 97 (range of individual sites)	2024	No	Byproduct of drinking water disinfection.
<b>Household Plumbing Contaminants</b>							
Copper (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.088 (90 <sup>th</sup> percentile)	0.007 to 0.13	Aug-23	No	Corrosion of household plumbing systems

**Unregulated Contaminant Testing**

Your drinking water from Russell Water and Ashland Water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those for which EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours. None of the contaminants were detected at the time of testing in Russell. One of thirty contaminants was detected in Ashland’s water (see table with Ashland Water’s results).



Regulated Contaminant Test Results			Russell Water Company					
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
Alpha emitters [4000] (pCi/L)	15	0	2.61	2.61	to	2.61	May-20	No Erosion of natural deposits
Combined radium (pCi/L)	5	0	0.907	0.907	to	0.907	May-20	No Erosion of natural deposits
<b>Inorganic Contaminants</b>								
Barium [1010] (ppm)	2	2	0.036	0.036	to	0.036	May-24	No Drilling wastes; metal refineries; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.62	0.62	to	0.62	May-24	No Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	0.529	0.529	to	0.529	Sep-24	No Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfectants/Disinfection Byproducts and Precursors</b>								
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.06 (lowest average)	0.59	to	1.48 (monthly ratios)	2024	No Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.								
<b>Other Constituents</b>								
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement		Lowest Monthly %	Violation	Likely Source of Turbidity	
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.22		100	No	Soil runoff	

Regulated Contaminant Test Results			Ashland Water Works						
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
<b>Inorganic Contaminants</b>									
Barium [1010] (ppm)	2	2	0.033	0.033	to	0.033	Mar-24	No Drilling wastes; metal refineries; erosion of natural deposits	
Fluoride [1025] (ppm)	4	4	0.85	0.85	to	0.85	Mar-24	No Water additive which promotes strong teeth	
Nitrate [1040] (ppm)	10	10	0.51	0.51	to	0.51	Feb-24	No Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits	
<b>Disinfectants/Disinfection Byproducts and Precursors</b>									
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	1.41 (lowest average)	1.09	to	1.69 (monthly ratios)	2024	No Naturally present in environment.	
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.									
<b>Other Constituents</b>									
Turbidity (NTU) TT * Representative samples	Allowable Levels		Highest Single Measurement		Lowest Monthly %	Violation	Likely Source of Turbidity		
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.134		100	No	Soil runoff		
<b>Unregulated Contaminants (UCMR 5)</b>			<b>average</b>	<b>range (ppb)</b>		<b>date</b>			
perfluoropentanoic acid (PFPeA)			0.011	0	to	0.024	Nov-24		