

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.



Calvert City Water System Water Quality Report 2025

For previous reports include year.
Example: tapwaterinfo.com/2024/calvertcity

Water System ID: KY0790056
Superintendent: Bobby Henson
CCR Contact: Bobby Henson
Phone: 270-395-7138

Mailing address:
P.O. Box 36
Calvert City, KY 42029

Meeting location and time:
City Hall – 861 East 5th Ave.
Third Thursday each month at 4:30 PM

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases,

radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health

Source Information:

The source of water used by the Calvert City Municipal Water System is groundwater obtained from four wells located east of the corporate limits of Calvert City. The aquifer is comprised of Quaternary Period continental deposits and alluvial sands and gravels. The Calvert City Water System has implemented a Wellhead Protection Plan (WHPP). A susceptibility analysis included in the plan characterizes the risk for potential contamination of the aquifer as a medium risk. Potential contamination sources include spills of hazardous materials along the adjacent railroad and highways, leaking fuel storage tanks, agriculture activities and on-site wastewater treatment systems. The plan provides procedures for emergency response and notification should a release or spill of hazardous materials occur within the approved wellhead protection area. Calvert Water will continue working with the Kentucky Dept. of Environmental Protection to verify that businesses and industries located in the wellhead protection area implement best management practices to reduce the potential for a release of hazardous materials to the environment. A copy of the WHPP is on file for public review at City Hall.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can

be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information about Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Service Line Inventory Information:

To address lead in drinking water, EPA requires that all community water systems develop and maintain an inventory of service line materials. We have completed a service line inventory (SLI) and it is available for review at our office.

Lead Sample Results Availability Information:

We are required to periodically sample water from customer taps to determine lead and copper levels. EPA sets the lead action level at 0.015 mg/L (15 ppb). For a water system to be in compliance, at least 90% of tap water samples must have lead levels below this limit. This report contains the 90th percentile and range of our most recent sampling. The individual results for each location sampled can be reviewed at our office.

We are only required to test for some contaminants periodically, so the results listed in this report may not be from the previous year. Only detected contaminants are included in this report. For a list of all contaminants we test for please contact us. Copies of this report are available upon request by contacting our office.

Regulated Contaminant Test Results								Calvert City Municipal Water System	
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination		
Barium [1010] (ppm)	2	2	0.028	0.028 to 0.028	Feb-23	No	Drilling wastes; metal refineries; erosion of natural deposits		
Fluoride [1025] (ppm)	4	4	0.65	0.65 to 0.65	Feb-23	No	Water additive which promotes strong teeth		
Nickel (ppb) (US EPA remanded MCL in February 1995)	N/A	N/A	7	7 to 7	Feb-23	No	N/A		
Nitrate [1040] (ppm)	10	10	0.602	0.602 to 0.602	Nov-25	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits		
Disinfectants/Disinfection Byproducts and Precursors									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	0.99 (highest average)	0.84 to 1.26	2025	No	Water additive used to control microbes.		
HAA (ppb) (Stage 2) [Haloacetic acids] (Annual Sample)	60	N/A	4 (high site)	0 to 4 (range of individual sites)	2025	No	Byproduct of drinking water disinfection		
TTHM (ppb) (Stage 2) [total trihalomethanes] (Annual Sample)	80	N/A	8 (high site)	5 to 8 (range of individual sites)	2025	No	Byproduct of drinking water disinfection.		
Household Plumbing Contaminants									
Copper (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.161 (90 th percentile)	0.02 to 0.187	Aug-25	No	Corrosion of household plumbing systems		
Lead (ppb) Round 1 sites exceeding action level 0	AL = 15	0	3 (90 th percentile)	0 to 10	Aug-25	No	Corrosion of household plumbing systems		



Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

Fluoride (added for dental health)	Average	Range of Detection
	0.8	0.7 to 0.86
Sodium (EPA guidance level = 20 mg/L)	10.0	10 to 10

Secondary contaminants do not have a direct impact on the health of consumers. They are being included to provide additional information about the quality of the water.

Secondary Contaminant	Maximum Allowable Level	Report Level	Range of Detection	Date of Sample
Chloride	250 mg/l	11	11 to 11	Feb-25
Copper	1.0 mg/l	0.021	0.021 to 0.021	Feb-25
Corrosivity	Noncorrosive	-0.224	-0.224 to -0.224	Feb-25
Fluoride	2.0 mg/l	0.76	0.76 to 0.76	Feb-25
pH	6.5 to 8.5	7.41	7.41 to 7.41	Feb-25
Sulfate	250 mg/l	22.1	22.1 to 22.1	Feb-25
Total Dissolved Solids	500 mg/l	238	238 to 238	Feb-25

Our water system failed to comply with a required testing procedure. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During November 2025, we did not complete all monitoring or testing for total coliform bacteria, and therefore cannot be sure of the quality of your drinking water during that time.

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We are required to collect five routine bacteriological samples per month. During the month of November 2025, we inadvertently failed to collect and submit one of the total coliform bacteria samples. Only four of the five required were collected. Procedures have been established to prevent similar situations in the future.

For more information, please contact Bobby Henson at 270-395-7138 or P.O. Box 36 Calvert City, KY 42029.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.